



BGNM Checklist Summary

Program Base: **ANSI National Green Building Standard**

Project Information

| | |
|------------------|---|
| Builder: | Home Construction & Consulting Services |
| Project Address: | 5618 Upland Meadows Rd, Rio Rancho NM |
| Date: | 29-Nov-10 |
| Green Verifier: | Adam Walker |
| BGNM Certifier: | Steve Hale |

| Sections | Points Awarded | Points Required | | | |
|---|----------------|-----------------|--------|------|---------|
| | | Bronze | Silver | Gold | Emerald |
| Approved Third party Verification required for all points claimed | | | | | |
| Chapter 5: Lot Design | 120 | 39 | 66 | 93 | 119 |
| Chapter 6: Resource Efficiency | 101 | 45 | 79 | 113 | 146 |
| Chapter 7: Energy Efficiency | 116 | 30 | 60 | 100 | 120 |
| Chapter 8: Water Efficiency | 50 | 14 | 26 | 41 | 60 |
| Chapter 9: Indoor Environmental Quality | 68 | 36 | 65 | 100 | 140 |
| Chapter 10: Owner Education | 13 | 8 | 10 | 11 | 12 |
| Required Extra Points Accumulated From All Seven Sections | | 50 | 100 | 100 | 100 |
| Total Points | 468 | 222 | 406 | 558 | 697 |

Certified Level Silver

| | | | |
|-----------------------------------|--------------------------|------------|-------------------|
| Square Footage | <u>1815</u> | HERS Index | <u>53</u> |
| Build Green Certifier's Signature | <u><i>Steve Hale</i></u> | Date: | <u>11/29/2010</u> |
| Verifiers Signature (optional) | _____ | Date: | _____ |
| Builders Signature | _____ | Date: | _____ |

Build Green NM Certification Program GREEN HOME CERTIFICATION



This is to signify that the new home located at
5618 Upland Meadows Rd. Rio Rancho NM


built by,

**Home Construction & Consulting
Services LLC**

Has been CERTIFIED as a

Silver LEVEL GREEN HOME

The Build Green NM certifies that this house, as originally built, is in substantial conformance with the ANSI National Green Building Standard.


Steve Hale, Build Green NM Director **11/29/2010** **Adam Walker**
Issuance Date Rater or Verifier

This certification is not a representation, warranty, or guarantee of home performance.
For details on builder's warranty, consult the builder.

| | |
|---|------|
| Sq Ft of Residence | 1815 |
| HERS Index | 53 |
| Building leakage (ACH50) | 2.3 |
| Ventilation (ASHRAE 62.2) (105 cfm X 11 hrs) | Met |
| Water Saving | |
| Toilets (1.28 gpf) | Yes |
| Lavatory Faucets (1.5 gpm) | Yes |
| Shower Heads (2.5 gpm) | Yes |
| Drip Irrigation installed | Yes |